


Stack Emissions

All sulphur dioxide and nitrogen dioxide emissions were below the permitted levels. Opacity of both units is being carefully monitored. A provision correlation curve for the CEMS was installed and being monitored. However, all values were still below the Thai legal limit and will not impact TSP and PM10 concentrations in ambient air at the 4 AQMS stations.

- **Sulfur Dioxide (SO₂) : June 2007**



- **Nitrogen Oxides (NO_x) : June 2007**

